

## **PWSD 6 of Clay County – Water Connection Information**

### **Water Service Connections**

Water service connections shall be made in accordance with the District’s water service connection policy.

### **Approved Materials Water Service Connections**

All water service line material is required to be Blue Polyethylene AWWA C901-20 (PE) Pressure Pipe & Tubing, 3/4” (19mm) through 3” (76mm). Service line Poly and Tracer Wire **NOT** included in Service Connection purchase. Any deviations in service line materials must be approved in advance, in writing, by District Staff. All other Water Service line materials will be included in Water Service purchase (Brass Saddle, Corporation Stop, Meter Setter, Meter Pit, Meter Pit Lid and Ring, Water Meter, Transmitter). Materials will be delivered to new service address upon request.

### **Water Service Connection Process**

Applications for new meter sets can be found at [pwsd6clayco.com](http://pwsd6clayco.com) or in person at District office. Once application is approved and all fee’s paid, developer, contractor, homeowner will be responsible for hiring a licensed plumber to excavate the District water main, and make safe entry for District staff to enter excavation and perform water service tap. Plumber will be responsible for laying service line materials and meter pit, with tracer wire (not provided by District). Water tap to be performed by District staff. **48 Hours notice** shall be provided **BEFORE** intent to excavate and make service connection. After the tap and service line installed, an inspection shall be completed by District Staff. If service line materials or craftsmanship is deemed to be defective, corrections will be required before meter will be set and account will be activated. If inspected and approved, the water meter will be set by District Staff and approval to backfill will be given. **Do not** backfill service line until inspected and approved by District Staff. All final grades, excavations, and backfilling of excavated areas will be the responsibility of developer, homeowner, or plumber.

### **Water Service Requirements**

- Water service line should be laid at a minimum depth of 36” to avoid freezing.
- Water service line must have tracer wire.
- Water meter must be at least 18” lower than the meter lid to avoid freezing.

**48 Hour’s notice** must be given to office **BEFORE** intent to excavate for Water Service.

Office: 816-628-3220

Website: [pwsd6clayco.com](http://pwsd6clayco.com)

### **Materials Provided**

Brass Saddle  
Corporation Stop  
Meter Pit / Lid and ring  
Meter Setter  
Water Meter and Transmitter

### **Materials Excluded**

Blue Poly  
Tracer Wire